

Laborator inregistrat la Ministerul Sanatatii Bucuresti nr. 336 / 2014 pentru monitorizare de control
Raport de analiza Nr.1296 Data 06.09.2016 PLOPENI

BENEFICIAR SUCURSALA PLOPENI

PUNCT DE RECOLTARE /SURSA statie

DATA si ORA; PRELEVARII 06.09.2016 ;10

DATA EFECTUARII ANALIZEI 06.09.2016

Metoda de prelevare : conf. SR EN ISO 5667 – 1/2007; SR EN ISO 5667 – 3/2013; SR EN ISO 19458/2007;

Nr. crt.	Indicatori analizati	Standardul de analiza	Valori maxim admise	Rezultate obtinute
1	Miros	SR EN 1622 / 2007	Nici o modificare anormala	n.m.a.
2	Gust	SR EN 1622 / 2007	Nici o modificare anormala	n.m.a.
3	Culoare	SR EN ISO 7887 / 2012	Nici o modificare anormala	n.m.a.
4	Turbiditate (UNT)	SR EN ISO 7027 / 2001	≤ 5	0,158
5	pH (unit. pH)	SR EN ISO 10523:2012	≥ 6,5 ; ≤ 9,5	8,31
6	Conductivitate (μS/cm)	SR EN 27888 / 1997	2500	322
7	Clor rezidual liber si clor total (mg/l)	SR EN ISO 7393-2 / 2002	0,50 - iesire statie 0,10 – capat de retea	0,52/0,52
8	Amoniu (mg/l)	SR EN 7150-1 / 2001	0,50	0
9	Nitriti (mg/l)	SR EN 26777:2002	0,10 - iesire statie 0,50 - retea	0
10	Nitrati (mg/l)	SR EN 7890-3 / 2000	50	0
11	N formule	Legea 458/2002 republicata	≤ 1	0
12	Cloruri (mg/l)	SR ISO 9297 / 2001	250	21,98
13	Duritate totala (gr.germ.)	SR ISO 6059 / 2008	≥ 5	9,31
14	Aluminiu (μg/l)	SR ISO 10566 / 2001	200	41,26
15	Indice de permanganat(mgO ₂ /l)	SR EN ISO 8467 / 2001	5,0	2,56
16	Fier (μg/l)	SR ISO 6332 / 1996/C91/2006	200	---
17	Nr.colonii-22 ^o C (UFC / ml)	SR EN ISO 6222 / 2004	Nici o modificare anormala	n.m.a
18	Nr.colonii-37C (UFC / ml)	SR EN ISO 6222 / 2004	Nici o modificare anormala	n.m.a.
19	Bacterii coliforme (nr./100ml)	SR EN ISO 9308-1/2004	0	0
20	Escherichiacoli (nr./100ml)	SR EN ISO 9308-1/2004	0	0
21	Enterococi (nr./100ml)	SR EN ISO 7899-2/2002	0	0
22	Clostridium perfringens	Legea 458/2002 republicata	0	0


Nota:

- Raportul de analiza se refera numai la proba de apa specificata.
- Este interzisa reproducerea partiala sau totala a acestui raport de analiza fara aprobarea emitentului.

Sef laborator,



Analiza efectuata,



F-011-LF

Laborator inregistrat la Ministerul Sanatatii Bucuresti nr. 336 / 2014 pentru monitorizare de control
Raport de analiza Nr. 1297 Data 06.09.2016 MALAESTII DE JOS

BENEFICIAR SUCURSALA PLOPENI

PUNCT DE RECOLTARE /SURSA retea mag. AMI

DATA si ORA; PRELEVARI 06.09.2016 ; 10

DATA EFECTUARII ANALIZEI 06.09.2016

Metoda de prelevare : conf. SR EN ISO 5667 – 1/2007; SR EN ISO 5667 – 3/2013; SR EN ISO 19458/2007;

Nr. crt.	Indicatori analizati	Standardul de analiza	Valori maxim admise	Rezultate obtinute
1	Miros	SR EN 1622 / 2007	Nici o modificare anormala	n.m.a.
2	Gust	SR EN 1622 / 2007	Nici o modificare anormala	n.m.a.
3	Culoare	SR EN ISO 7887 / 2012	Nici o modificare anormala	n.m.a.
4	Turbiditate (UNT)	SR EN ISO 7027 / 2001	≤ 5	1,28
5	pH (unit. pH)	SR EN ISO 10523:2012	≥ 6,5 ; ≤ 9,5	8,03
6	Conductivitate (μS/cm)	SR EN 27888 / 1997	2500	289
7	Clor rezidual liber si clor total (mg/l)	SR EN ISO 7393-2 / 2002	0,50 - iesire statie 0.10 – capat de retea	0,23/0,24
8	Amoniu (mg/l)	SR EN 7150-1 / 2001	0,50	0,009
9	Nitriti (mg/l)	SR EN 26777:2002	0.10 - iesire statie 0,50 - retea	0,007
10	Nitrati (mg/l)	SR EN 7890-3 / 2000	50	1,3
11	N formule	Legea 458/2002 republicata	≤ 1	0,028
12	Cloruri (mg/l)	SR ISO 9297 / 2001	250	---
13	Duritate totala (gr.germ.)	SR ISO 6059 / 2008	≥ 5	11,1
14	Aluminiu (μg/l)	SR ISO 10566 / 2001	200	53,14
15	Indice de permanganat(mgO ₂ /l)	SR EN ISO 8467 / 2001	5,0	1,6
16	Fier (μg/l)	SR ISO 6332 / 1996/C91/2006	200	---
17	Nr.colonii-22°C (UFC / ml)	SR EN ISO 6222 / 2004	Nici o modificare anormala	n.m.a
18	Nr.colonii-37C (UFC / ml)	SR EN ISO 6222 / 2004	Nici o modificare anormala	n.m.a.
19	Bacterii coliforme (nr./100ml)	SR EN ISO 9308-1/2004	0	0
20	Escherichiacoli (nr./100ml)	SR EN ISO 9308-1/2004	0	0
21	Enterococi (nr./100ml)	SR EN ISO 7899-2/2002	0	0
22	Clostridium perfringens	Legea 458/2002 republicata	0	0


Nota:

1. Raportul de analiza se refera numai la proba de apa specificata.
2. Este interzisa reproducerea partiala sau totala a acestui raport de analiza fara aprobarea emitentului.

Sef laborator



Analiza efectuata,



F-011-LF

Laborator inregistrat la Ministerul Sanatatii Bucuresti nr. 336 / 2014 pentru monitorizare de control
Raport de analiza Nr.1408 Data 27.09.2016 DUMBRAVESTI Han Eden Land

BENEFICIAR SUCURSALA PLOPENI

PUNCT DE RECOLTARE /SURSA retea

DATA si ORA; PRELEVARII 27.09.2016 ;10

DATA EFECTUARII ANALIZEI 27.09.2016

Metoda de prelevare : conf. SR EN ISO 5667 – 1/2007; SR EN ISO 5667 – 3/2013; SR EN ISO 19458/2007;

Nr. crt.	Indicatori analizati	Standardul de analiza	Valori maxim admise	Rezultate obtinute
1	Miros	SR EN 1622 / 2007	Nici o modificare anormala	n.m.a.
2	Gust	SR EN 1622 / 2007	Nici o modificare anormala	n.m.a.
3	Culoare	SR EN ISO 7887 / 2012	Nici o modificare anormala	n.m.a.
4	Turbiditate (UNT)	SR EN ISO 7027 / 2001	≤ 5	0,314
5	pH (unit. pH)	SR EN ISO 10523:2012	≥ 6,5 ; ≤ 9,5	8,77
6	Conductivitate (μS/cm)	SR EN 27888 / 1997	2500	326
7	Clor rezidual liber si clor total (mg/l)	SR EN ISO 7393-2 / 2002	0,50 - iesire statie 0,10 – capat de retea	0,39/0,4
8	Amoniu (mg/l)	SR EN 7150-1 / 2001	0,50	0
9	Nitriti (mg/l)	SR EN 26777:2002	0,10 - iesire statie 0,50 - retea	0
10	Nitrati (mg/l)	SR EN 7890-3 / 2000	50	0
11	N formule	Legea 458/2002 republicata	≤ 1	0
12	Cloruri (mg/l)	SR ISO 9297 / 2001	250	----
13	Duritate totala (gr.germ.)	SR ISO 6059 / 2008	≥5	9,76
14	Aluminiu (μg/l)	SR ISO 10566 / 2001	200	40,869
15	Indice de permanganat(mgO ₂ /l)	SR EN ISO 8467 / 2001	5,0	3,2
16	Fier (μg/l)	SR ISO 6332 / 1996/C91/2006	200	----
17	Nr.colonii-22°C (UFC / ml)	SR EN ISO 6222 / 2004	Nici o modificare anormala	----
18	Nr.colonii-37C (UFC / ml)	SR EN ISO 6222 / 2004	Nici o modificare anormala	----
19	Bacterii coliforme (nr./100ml)	SR EN ISO 9308-1/2004	0	0
20	Escherichiacoli (nr./100ml)	SR EN ISO 9308-1/2004	0	0
21	Enterococi (nr./100ml)	SR EN ISO 7899-2/2002	0	0
22	Clostridium perfringens	Legea 458/2002 republicata	0	----


Nota:

1. Raportul de analiza se refera numai la proba de apa specificata.
2. Este interzisa reproducerea partiala sau totala a acestui raport de analiza fara aprobarea emitentului.

Sef laborator,



Analiza efectuata



Laborator inregistrat la Ministerul Sanatatii Bucuresti nr. 336 / 2014 pentru monitorizare de control
Raport de analiza Nr. 1407 Data 27.09.2016 PLOPENI PIATA

BENEFICIAR SUCURSALA PLOPENI

PUNCT DE RECOLTARE /SURSA retea

DATA si ORA; PRELEVARII 27.09.2016 ;10

DATA EFECTUARII ANALIZEI 27.09.2016

Metoda de prelevare : conf. SR EN ISO 5667 – 1/2007; SR EN ISO 5667 – 3/2013; SR EN ISO 19458/2007;

Nr. crt.	Indicatori analizati	Standardul de analiza	Valori maxim admise	Rezultate obtinute
1	Miros	SR EN 1622 / 2007	Nici o modificare anormala	n.m.a.
2	Gust	SR EN 1622 / 2007	Nici o modificare anormala	n.m.a.
3	Culoare	SR EN ISO 7887 / 2012	Nici o modificare anormala	n.m.a.
4	Turbiditate (UNT)	SR EN ISO 7027 / 2001	≤ 5	0,408
5	pH (unit. pH)	SR EN ISO 10523:2012	≥ 6,5 ; ≤ 9,5	8,76
6	Conductivitate (μS/cm)	SR EN 27888 / 1997	2500	335
7	Clor rezidual liber si clor total (mg/l)	SR EN ISO 7393-2 / 2002	0,50 - iesire statie 0,10 – capat de retea	0,3/0,3
8	Amoniu (mg/l)	SR EN 7150-1 / 2001	0,50	0
9	Nitriti (mg/l)	SR EN 26777:2002	0,10 - iesire statie 0,50 - retea	0,002
10	Nitrati (mg/l)	SR EN 7890-3 / 2000	50	0
11	N formule	Legea 458/2002 republicata	≤ 1	0,0007
12	Cloruri (mg/l)	SR ISO 9297 / 2001	250	----
13	Duritate totala (gr.germ.)	SR ISO 6059 / 2008	≥ 5	9,31
14	Aluminiu (μg/l)	SR ISO 10566 / 2001	200	40,168
15	Indice de permanganat(mgO ₂ /l)	SR EN ISO 8467 / 2001	5,0	2,24
16	Fier (μg/l)	SR ISO 6332 / 1996/C91/2006	200	----
17	Nr.colonii-22 ^o C (UFC / ml)	SR EN ISO 6222 / 2004	Nici o modificare anormala	----
18	Nr.colonii-37C (UFC / ml)	SR EN ISO 6222 / 2004	Nici o modificare anormala	----
19	Bacterii coliforme (nr./100ml)	SR EN ISO 9308-1/2004	0	0
20	Escherichiacoli (nr./100ml)	SR EN ISO 9308-1/2004	0	0
21	Enterococi (nr./100ml)	SR EN ISO 7899-2/2002	0	0
22	Clostridium perfringens	Legea 458/2002 republicata	0	----


Nota:

- Raportul de analiza se refera numai la proba de apa specificata.
- Este interzisa reproducerea partiala sau totala a acestui raport de analiza fara aprobarea emitentului.

Sef laborator,



Analiza efectuata,



F-011-LF

Laborator inregistrat la Ministerul Sanatatii Bucuresti nr. 336 / 2014 pentru monitorizare de control
Raport de analiza Nr.1406 Data 27.09.2016 PLOPENI

BENEFICIAR SUCURSALA PLOPENI

PUNCT DE RECOLTARE /SURSA statie

DATA si ORA; PRELEVARII 27.09.2016 ;10

DATA EFECTUARII ANALIZEI 27.09.2016


Metoda de prelevare : conf. SR EN ISO 5667 – 1/2007; SR EN ISO 5667 – 3/2013; SR EN ISO 19458/2007;

Nr. crt.	Indicatori analizati	Standardul de analiza	Valori maxim admise	Rezultate obtinute
1	Miros	SR EN 1622 / 2007	Nici o modificare anormala	n.m.a.
2	Gust	SR EN 1622 / 2007	Nici o modificare anormala	n.m.a.
3	Culoare	SR EN ISO 7887 / 2012	Nici o modificare anormala	n.m.a.
4	Turbiditate (UNT)	SR EN ISO 7027 / 2001	≤ 5	0,192
5	pH (unit. pH)	SR EN ISO 10523:2012	≥ 6,5 ; ≤ 9,5	8,5
6	Conductivitate (μS/cm)	SR EN 27888 / 1997	2500	327
7	Clor rezidual liber si clor total (mg/l)	SR EN ISO 7393-2 / 2002	0,50 - iesire statie 0,10 – capat de retea	0,54/0,54
8	Amoniu (mg/l)	SR EN 7150-1 / 2001	0,50	0
9	Nitriti (mg/l)	SR EN 26777:2002	0,10 - iesire statie 0,50 - retea	0
10	Nitrati (mg/l)	SR EN 7890-3 / 2000	50	0
11	N formule	Legea 458/2002 republicata	≤ 1	0
12	Cloruri (mg/l)	SR ISO 9297 / 2001	250	21,27
13	Duritate totala (gr.germ.)	SR ISO 6059 / 2008	≥ 5	9,42
14	Aluminiu (μg/l)	SR ISO 10566 / 2001	200	31,36
15	Indice de permanganat(mgO ₂ /l)	SR EN ISO 8467 / 2001	5,0	2,56
16	Fier (μg/l)	SR ISO 6332 / 1996/C91/2006	200	----
17	Nr.colonii-22°C (UFC / ml)	SR EN ISO 6222 / 2004	Nici o modificare anormala	n.m.a
18	Nr.colonii-37C (UFC / ml)	SR EN ISO 6222 / 2004	Nici o modificare anormala	n.m.a.
19	Bacterii coliforme (nr./100ml)	SR EN ISO 9308-1/2004	0	0
20	Escherichiacoli (nr./100ml)	SR EN ISO 9308-1/2004	0	0
21	Enterococi (nr./100ml)	SR EN ISO 7899-2/2002	0	0
22	Clostridium perfringens	Legea 458/2002 republicata	0	0

Nota:

- Raportul de analiza se refera numai la proba de apa specificata.
- Este interzisa reproducerea partiala sau totala a acestui raport de analiza fara aprobarea emitentului.

Sef laborator,



Analiza efectuata,

