

**HIDRO PRAHOVA**  
OPERATOR REGIONAL DE APAStr. Stefan Greceanu nr.1, Ploiesti  
Tel.0244/529474 ;Fax. 0244/529340**LABORATORUL FINTINELE - MIZIL**  
Fntinele , DJ 102 K,Km 1 (Vadu Sapat – Fintinele)  
jud.Prahova**Laborator inregistrat la Ministerul Sanatatii Bucuresti nr. 172/2010 pentru monitorizare de control****Raport de analiza** Nr 307 Data 9 05 2012 Urletii gradina  
O.P.BENEFICIAR Acursala Urletii PUNCT DE RECOLTARE /SURSA reteaDATA PRELEVARII 9 05 2012 DATA EFECTUARII ANALIZEI 9 05 2012

Metoda de prelevare : conf.SR ISO 5667 – 5 / 98

Nr. crt.	Indicatori analizati	Standardul de analiza	Valori maxim admise	Rezultate obtinute
1	Miros	SR EN 1622 / 2007	Nici o modificare anormala	u u a
2	Gust	SR EN 1622 / 2007	Nici o modificare anormala	u u a
3	Culoare	SR EN ISO 7887 / 2002	Nici o modificare anormala	u u a
4	Turbiditate (UNT)	SR EN ISO 7027 / 2001	≤ 5	0,62
5	pH (unit. pH)	SR EN ISO 10523 / 1997	≥ 6,5 ; ≤ 9,5	7,05
6	Conductivitate (μS/cm)	SR EN 27888 / 1997	2500	814
7	Clor rezidual liber (mg/l)	SR EN ISO 7393-2 / 2002	0,50 - iesire statie 0.10 – capat de retea	0,28
8	Amoniu (mg/l)	SR EN 7150-1 / 2001	0,50	0
9	Nitriti (mg/l)	SR EN 26777:2002	0.10 - iesire statie 0,50 - retea	0
10	Nitrati ( mg/l )	SR EN 7890-1 / 1998	50	2789
11	Cloruri (mg/l)	SR ISO 9297 / 2001	250	—
12	Duritate totala (gr.germ.)	SR ISO 6059 / 2008	≥5	20,19
13	Aluminiu (μg/l)	SR ISO 10566 / 2001	200	—
14	Indice de permanganat(mgO <sub>2</sub> /l)	SR EN ISO 8467 / 2001	5,0	1,28
15	Fier (μg/l)	SR ISO 6332 / C91 / 2006	200	—
16	Sulfati (mg/l)	STAS 3069 / 1987	250	—
17	Nr.colonii-22°C (UFC / ml)	SR EN ISO 6222 / 2004	Nici o modificare anormala	—
18	Nr.colonii-37C (UFC / ml)	SR EN ISO 6222 / 2004	Nici o modificare anormala	—
19	Bacterii coliforme (nr./100ml)	SR EN ISO 9308-1/2004	0	0
20	Escherichiacoli (nr./100ml)	SR EN ISO 9308-1/2004	0	0
21	Enterococi (nr./100ml)	SR EN ISO 7899-2/2002	0	0

**Nota:**

1. Raportul de analiza se refera numai la proba de apa specificata.
2. Este interzisa reproducerea partiala sau totala a acestui raport de analiza fara aprobarea emitentului.

Sef laborator,

Analiza efectuata,

F – 011 – LF